

**ACCESS CONTROLLED EGRESS DOOR WORKSHEET**

Date:

Project Name:

Contractor:

Project Location:

Address:

**2006 IBC/NJ Edition Building Code - 1008.1.3.4 - Access Controlled Egress Doors (Effective 2/20/2007)**  
**2002 NFPA 72 National Fire Alarm Code - 6.15.7 - Door Unlocking Devices (Effective 2/20/2007)**

Cite	Requirement	Complies	Plan Review Comments
1008.1.3.4	Permitted in Use A,B,E,M,R-1,R-2- Entrance Doors	Y N	
1008.1.3.4	Permitted in Use A,B,E,M,R-1,R-2- Tenant Entrance Doors	Y N	
1008.1.3.4.1	Egress Side Approach Sensor	Y N	
1008.1.3.4.1	Egress Side Approach Sensor Power Loss arranged to Unlock Door(s)	Y N	
1008.1.3.4.2	Loss of Power to Control Components on Access System arranged to Lock/Unlock Door(s)	Y N	
1008.1.3.4.2	Loss of Power to Control Components on Fire Alarm System arranged to Lock/Unlock Door(s)	Y N	
6.15.7.3	Loss of Primary Power to the Fire Alarm System	Y N	
6.15.7.3	Fire Alarm Secondary Power shall not maintain doors in locked condition	Y N	
1008.1.3.4.3	Manual Unlocking Device at 40-48" vertically above the floor	Y N	
1008.1.3.4.3	Manual Unlocking Device within 5 Feet of secured door(s)	Y N	
1008.1.3.4.3	Manual Unlocking Device Signage	Y N	
1008.1.3.4.3	Manual Unlocking Device Direct Interruption of Power to the Lock Independent of Access Control	Y N	
1008.1.3.4.3	Manual Unlocking Device Operation Door(s) Remain Unlocked for minimum of 30 Seconds	Y N	
1008.1.3.4.4	Actuation of Building Fire Alarm System Unlocks Door(s)	Y N	
6.15.7.2	Fire Alarm Signal from Fire Alarm System unlocks doors	Y N	
6.15.7.4	Unlocking prior to or concurrent with Public Mode Fire Alarm Notification Appliances	Y N	
1008.1.3.4.4	Door(s) Remain Unlocked Until Fire Alarm Reset	Y N	
1008.1.3.4.5	Actuation of Building Automatic Fire Sprinkler System Unlocks Door(s)	Y N	
1008.1.3.4.5	Actuation of Building Fire Detection System System Unlocks Door(s)	Y N	
1008.1.3.4.5	Doors Remain Unlocked Until Fire Alarm Reset	Y N	
1008.1.3.4.6	Entrance Doors in Uses A,B,E,M shall not be secured from egress side during periods that building is open to the general public.	Y N	
NJAC 5:23	Plans Submitted in Duplicate	Y N	
NJAC 5:23	Plans Signed and Sealed by NJ PE/RA- Class I and II Buildings or where exempt	Y N	
NJAC 5:23	Plans Signed and Sealed by NJ Lic Elect Contractor -Class III Buildings Only	Y N	
NJAC 5:23	Catalog Cut Sheets Submitted in Duplicate - NRTL Listings Evidenced	Y N	
NJAC 5:23	Fire Subcode Application Filed	Y N	
NJAC 5:23	Electrical Subcode Application Filed	Y N	
NJAC 5:23	NJ Certified/Licensed Fire Protection Contractor or NJ Licensed Electrical Contractor	Y N	

**PURSUANT TO N.J.A.C 5:23 - NON REQUIRED FORM - UTILIZED FOR PLAN REVIEW/INSPECTION USE ONLY**

Courtesy John Drucker - Fire Protection Subcode Official